

PUBLIC HEALTH ENGINEERING DEPARTMENT

WATER QUALITY TESTING LABORATORY

PUBLIC HEALTH ENGINEERING SUB DIVISION THANDLA -276177  
DIVISION-JHABUA (M.P.)

Sample Received from ..... Analysis Report No ..... 1753.....

कार्मलिय प्रचार्य एकुलव्य सादरी ..... Bill No ..... Date .....

आवासीय विद्यालय पेटलावद ..... Particulars of collection .....

जिला - झाबुआ (म.प्र.) ..... Date of collection ..... 21/01/2026.....

..... Date of Receipt ..... 21/01/2026.....

..... Date of Analysis ..... 21/01/2026.....

Description of samples -

- (1) विद्यालय - पेटलावद, एकुलव्य सादरी आवासीय विद्यालय पेटलावद लोडेशन - पुआ
- (2) .....
- (3) .....
- (4) .....
- (5) .....

S.No.	Parameters	Unit & Permissible limit as BIS 10500-2012	(1)	(2)	(3)	(4)	(5)
(A)	PHYSICAL						
1	Colour	5 TO 15 HAZAN	-				
2	Taste	Agreeable	-				
3	Odour	Unobjectional	-				
4	Turbidity	1 To 5 NTU	0.31				
(B)	CHIMICAL						
5	PH	PH SCALE ( 6.5 to 8.5)	7.0				
6	Specific Conductivity	Micro mhos/ Cm.	-				
7	Total Dissolved Solids	500 - 2000 mg/l	424				
8	Total Hardness (as co co3 )	200 - 600 mg/l	80				
9	Total Alkalinity	200 - 600 mg/l	80				
10	Chlorides (as cl )	250 -1000 mg/l	30				
11	Fluorides ( as F )	1.0 - 1.5 mg/l	0.18				
12	Nitrate ( as No3)	45 - 45 mg/l	NIL				
13	Iron Fe	0.3 -1.0 mg/l	NIL				
14	Residual Chlorine	0.2 -1.0 mg/l	0				
(c)	BACTERIOLOGICAL						
15	Total Coliform /100 ml.	Nil	-				
16	Feacal Coliform / 100 ml.	Nil	-				
(c)	OTHER TESTS						

*Banki*  
Assistant Engineer  
P.H.E. Sub division  
Thandla



*Hardy*  
Chemist  
P.H.E. Sub Division  
Thandla

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 63

Dated: 22-1-2026

It is certified that an inspection team headed by Ms. Suresh Meda, Chemist

(Name of Officers with designation) from Sub Divisional Thandla PHED

inspected the Eklavya Model Residential School Pethanad

(Name & Address of the school) on 21/01/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1753 dated 21/01/2026

of Sub Divisional Lab Thandla (PHED Lab) certified that the

Eklavya Model Residential School Pethanad Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 22/01/2027

Olanki  
Assistant Engineer  
H.E Sub Div Thandla

Signature with Seal: Olanki

Name : Rahul Solanki

Designation : Sub divisional officer P.H.E

Name & Address of the Office / Department : Thandla

To  
Eklavya Model Residential School  
Pethanad, Distt. Jabua (M.P.)  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

